

## **A few notes regarding the new CFN3 system.**

The CFN3 system is essentially a PC running Win/NT that is running a program that is communicating to the Site Controller III system that is contained on 2 PCB's internally installed in the same PC Tower. On the screen you will see a program running (minimized at the bottom of the screen or as a window in the middle of the screen). If it is minimized, you can click on the CFNIII Session in the task bar at the bottom to bring it up as a window on the screen.

Once the program is up as a window, you should be able to just press [Enter] and it should display the "signon:" prompt. From there it is almost identical to the CFNII system that you are somewhat familiar with. All of the commands (i.e. P PU, P DI, EN PU, P TIP, etc.) are identical.

Hint: If you do not get the "signon:" prompt when you press [Enter], make sure that the top of the window is blue and not gray. If it is gray, just move your pointer to the middle of the CFNIII window and left click once to make that the active screen that you are working on.

To shut down the program and the PC - Rather than clicking on the x button at the top of the screen, with the CFNIII window up on the screen, do an Alt-X to close out the CFNIII program (hold the ALT key and press X). That will shut the CFNIII program down and then you can go to the START menu and choose "Shut Down" or "Restart" depending on what you want to do.

To REBOOT the CFNIII (Site Controller III)- with the CFNIII window up on the screen, do an Alt-N (hold the ALT key and press N).

These are the main points and differences that you will notice. I'm sure that we will be talking at some point but hopefully things will go well (haven't heard from anyone so far so that is a good sign).

David C. Benner  
Fuel System Services  
Phone: (215) 723-7728  
Fax: (215) 723-2828  
Cell phone: (215) 480-0731  
E-mail: fss@verizon.net